



PVC PRESSURE WATER PIPE TRENCH

(STANDARD LAYING CONDITION "TYPE 5")
N.T.S.

NOTE: SEE STANDARD DETAIL M-1,
"TRACER WIRE CONNECTION PORT" FOR
TRACER WIRE PORT SPACING

* CLASS I, II, AND III AS DEFINED IN
ASTM D2487 AND THE PIPE BACKFILL
MATERIAL AND AGGREGATE BASE
COURSE FILL SECTION OF THE
SPECIFICATIONS

** STANDARD SIZE NO. 67 AS DEFINED
IN ASTM D448, MAXIMUM EMBEDMENT
PARTICLE SIZE SHALL NOT EXCEED
3/4 IN. FOR ANGULAR ROCK OR
1-1/2 IN. FOR ROUNDED ROCK

SPRINGDALE
WATER UTILITIES

526 OAK AVENUE • P.O. BOX 769 • SPRINGDALE, ARKANSAS • 72765-0769 • (479) 751-5751

STANDARD DETAILS
FOR
WATER CONSTRUCTION

DRAWN BY: JSB

DRAWING NO: S-49

DATE: AUGUST 2025